

**General Specification for Civil Engineering Works**

**2006 Edition**

**AMENDMENT NO. 1/2022**

**VOLUME 2**

**SECTION 22 WATER SUPPLY PIPEWORKS**

**MATERIALS**

- (a) Table 22.2 **Replace the wrapping temperature range (°C) in the twelfth cell of the second column of “45” with “55”.**

**Replace the in service temperature range (°C) in the thirteenth cell of the second column of “-5 to +45” with “-20 to +70”.**

**Quality Management & Standards Unit  
Civil Engineering and Development Department  
2 June 2022**