



**NOTES:**

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. ALL CONCRETE SHALL BE GRADE 20 / 20.
3. MOVEMENT JOINT TO BE PROVIDED AT 10 METRES INTERVALS, SEE STD. DRG. NO. C2004 FOR DETAILS.
4. MINIMUM COVER TO REINFORCEMENT SHALL BE 50 mm.
5. CONCRETE FINISH OR FACING MATERIALS AS SPECIFIED.
6. ALIGNMENT OF WALL AT ENDS SHALL BE ADJUSTED TO SUIT SITE CONDITIONS.
7. WING WALL SHALL HAVE THE SAME THICKNESS AND APPEARANCE AS THE ADJACENT WALL AND SHALL BE CONSTRUCTED AT THE SAME TIME AS THE ADJACENT WALL. THE MESH REINFORCEMENT OF THE WING WALL SHALL BE A CONTINUATION OF THE MESH REINFORCEMENT FROM THE ADJACENT WALL.
8. FOR SPECIFICATIONS OF GEOTEXTILE FILTER, SEE CLAUSE 7.212(7) IN GS 2020.

J	BIM OBJECT REVISION.	Original Signed	12.2025
H	NOTE 8 AMENDED.	Original Signed	08.2024
G	DRAWING TITLE AMENDED. NOTE 8 ADDED.	Original Signed	02.2008
F	NOTE 7 ADDED.	Original Signed	08.2007
E	NAME OF DEPARTMENT AMENDED.	Original Signed	01.2005
D	WING WALL ADDED.	Original Signed	01.2004
C	MINOR AMENDMENT.	Original Signed	12.2002
B	MINOR AMENDMENT.	Original Signed	08.2001
A	MINOR AMENDMENT.	Original Signed	3.94
REF.	REVISION	SIGNATURE	DATE

**CONCRETE PLANTER WALL**



**CIVIL ENGINEERING AND  
DEVELOPMENT DEPARTMENT**

**SCALE** 1 : 20

**DRAWING NO.**

**DATE** JAN 1991

**C2001J**