



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. ALL CONCRETE SHALL BE GRADE 20/20. THE USE OF RECYCLED AGGREGATES SHALL BE CONSIDERED.
3. ALL TUBING, POST AND FENCES SHALL BE HOT DIP GALVANIZED TO BS EN ISO 1461.
4. WELDS SHALL BE WIRE BRUSHED AND PAINTED WITH TWO COATS OF ALUMINIUM MASTIC PAINT.
5. ALL STEELWORK SHALL BE OF GRADE S275 TO BS EN 10025.

NOTATIONS:

- GMS - GALVANIZED MILD STEEL
- G.I. - GALVANIZED IRON

BARBED WIRE SEE
DRG NO. C1006

GATE TYPE I

C	NOTE 5 AMENDED	Original Signed	09.2018
B	NOTE 3 AMENDED; NOTE 5 ADDED	Original Signed	03.2015
REF.	REVISION	SIGNATURE	DATE

CEDD
CIVIL ENGINEERING AND DEVELOPMENT DEPARTMENT

SCALE 1 : 25	DRAWING NO. C1007C
DATE JAN 1991	