

General Specification for Civil Engineering Works**2020 Edition****AMENDMENT NO. 1/2022****VOLUME 2****SECTION 22 WATER SUPPLY PIPEWORKS****MATERIALS**

- (a) Table 22.2 **Replace the wrapping temperature range (°C) in the twelfth cell of the second column of “45” with “55”.**

Replace the in service temperature range (°C) in the thirteenth cell of the second column of “-5 to +45” with “-20 to +70”.

**Quality Management & Standards Unit
Civil Engineering and Development Department
2 June 2022**